



# **EDF NPPs Post-Fukushima Complementary Safety Assessments**

**Jean-Luc Provost  
NPP Operation Division  
EDF-Generation**



# 1 - Context and issues

- **Fukushima Accident on March 11, 2011**
- **On March 23**, the French Prime Minister requests the French Regulator to conduct an audit of the plants in France,
  - while considering the work undertaken by European Safety Authorities
  - following a transparent procedure in accordance with the transparency Law
  - covering 5 areas: floods, earthquakes, loss of water supply, loss of electric power supply and operational management of accidents
- **With its decision on May 5, 2011**, the Regulator asks EDF to conduct a “Complementary Safety Assessment (CSA) “ of its nuclear installations
  - September 15th, 2011, for the power reactors currently operating, under construction, or being planned in France
  - September 15th, 2012, for the other nuclear installations

# EDF has submitted its reports to the Regulator

- ▶ **19 EDF reports** (sites currently operating and those that are under construction) have been submitted to the French Nuclear Regulatory Body, adding up to 7000 pages
  
- ▶ These assessments are resulting from the work of **more than 300 engineers during 4 months**, gathering competences in the fields of R&D, engineering and operation


## 2 - The basis of the analysis : the defense-in-depth

- ▶ **3 layers of defense-in-depth guarantee safety functions within the nuclear plants:**
  - **1st layer:** systems providing protection from natural events (earthquake, flooding, wind, etc.)
  - **2nd layer:** systems and procedures dealing with loss of cooling water or electricity (back-up diesel generators, back-up firefighting circuits, etc.)
  - **3rd layer:** barriers to limit the consequences of any degradation of fuel and containment integrity (hydrogen re-combiners, cesium filters, etc...)


# The Complementary Safety Assessments : a two-step analysis

**5 fields have been assessed:**

- Earthquake
- Flooding
- Loss of cooling water
- Loss of electric power supply
- Management of severe accidents



# Principle for assessing the resistance of installations to flooding



# Assessment of resistance of installations to earthquakes : Fessenheim example

## ➤ Reassessment of the present design

- Historic earthquake (SMHV) :
  - ➔ 6.2 on the Richter scale
- Earthquake with increased security (SMS):
  - ➔ 6.7 on the Richter scale (energy X 5)

## ➤ Analysis beyond the present design

- For nuclear buildings :
  - ➔ 7.2 on the Richer scale (energy x 25)
- For electrical buildings :
  - ➔ reinforcement beyond the referential of some electrical equipments required in case of extreme situations

# Assessment of resistance to station blackout

## ➤ Reactor

- **Time before beginning of core melting**
  - ➔ with one SG auxiliary feedwater pump : from 1 day to 1.5 day
  - ➔ without any operating pump : a few hours
- **Time before significant radioactive release (after core meltdown)**
  - ➔ through containment depressurization: 1 to 3 days through the venting filter (retention of 99.9% of cesium)
  - ➔ through breakthrough of basement by corium : a couple of days

## ➤ Spent fuel pool

- **Time before beginning of fuel uncover :**
  - ➔ from 1 to 5 days, depending on fuel inventory



# CSA results : earthquake and flood

- **Complementary modifications proposed by EDF**
  - **Protection of buildings (sealed perimeter):**
    - ➔ elevation above the 0-meter level
  - **Reinforcements or raising of dams, dikes**
  - **Reinforcement of electrical equipment robustness**
  - **Reinforcement of the flood protection for electrical switchyards**
  - **Reinforcement of supports and anchorages**
  - **Coupling between buildings**

# CSA results : loss of cooling water and electric power supply

➤ **Complementary modifications proposed by EDF  
to avoid fuel melting (reactors) or uncovering (spent fuel pools)**

- **Additional water supply (protected)**

- From groundwater or other water sources (basins...)

- **1 Additional Diesel generator (protected)**


- per unit
- Supplying the minimum required I&C, injection pumps to the SG, to the primary circuit and to the spent fuel pool

# Limitation of release in the environment

► In order to limit the consequences of a highly unlikely core melting

⇒ Design improvement : equipment to limit the radiological consequences in the environment in case of release


Venting the containment building via a filter enables to quantify the released activity and ensures to have a leak tight containment again after venting



# Limitation of the hydrogen explosion risk

► In order to limit the consequences of a highly unlikely core melting

⇒ Installation of additional equipment




For instance : 24 recombiners in a 900 MW reactor building

# Implementation of a Nuclear Rapid-Response Force



**Objectives:** to re-establish and/or maintain reactor cooling with the aim of avoiding any core fusion or any significant release

**Missions:**



# Crisis management reinforcement

## ➤ Crisis buildings implementation

- Ensure the operational aspect of the current safety building in case of earthquake
- Implement an appropriate crisis management building
  - advanced command and work building large enough and adequately equipped to manage the crisis on a long term basis
- Implement a base for assistance
  - Organisation of the logistics for the intervention of the Nuclear Rapid Response Force

# Schedule for implementation of the post-Fukushima actions

➔ **Modifications will be implemented according to the following schedule:**

- ❑ **Short term (2012-2015)** : Nuclear Rapid Response Force, water supply, temporary Diesel Generators,
- ❑ **Medium term (2016-2020)** : final Diesel Generators, final protected water supply, ...
- ❑ **Long term (>2020)**

➔ **Complementary studies will mainly be performed in 2011-2012**

**For some important modifications, temporary measures will be taken before their implementation.**

# Strong points supporting the robustness of the EDF nuclear facilities

- **Initial PWR NPP design**: good intrinsic robustness
- **Continued improvement of safety** : periodic inspections and “10 years” safety reevaluations, based on feedback (national : severe storm in 1999, heat wave in 2003..., and international : TMI, Chernobyl, ...) and knowledge improvements
- **Standardization of the EDF fleet**: homogeneous level of safety of all plants
- **Quality of plant operations**: operation, maintenance, preparation for emergency crisis (local and national)
- **EDF industrial organization** : integrated designer-operator mastering the design and improvement of plants,
- **Quality of supply chain** : selection, qualification and permanent monitoring of suppliers



# Main conclusions

- ▶ Following this work, EDF confirms **the presently good level of safety** for all Nuclear Power Plants
- ▶ **The new analyses** led EDF to propose to the French Nuclear Regulator **supplementary measures**, taking into account potential situations even worse than the design basis assumptions
- ▶ These analyses will enable **to improve even more the good level of safety** at EDF's nuclear power plants